

# Notice of Testing and Classification

|                              |                                                                    |
|------------------------------|--------------------------------------------------------------------|
| <b>COMPANY</b>               | JOSÉ LUIS MONTES SUÁREZ-BARANDILLAS TURIASSO                       |
| <b>ADDRESS</b>               | Pol. Ind. C/ Castilla y León 39<br>50500 TARAZONA (ZARAGOZA) SPAIN |
| <b>ASSOCIATED REPORT No.</b> | 14_05792-1-a                                                       |

## TESTED SAMPLE

Railing base 40x20 «ref. 8001»

## TEST REQUESTED

The testing requested regards **shear load**, carried out in accordance with internal procedures. Load is applied resulting in breakage of the part in order to verify the maximum allowable load.

## RESULT

| Test       | Maximum load (N)* |
|------------|-------------------|
| Shear load | 11240             |

\*Equivalence 10 N = 1 kg

|                            |            |
|----------------------------|------------|
| <b>Date of test</b>        | 14/04/2014 |
| <b>Date of issue</b>       | 14/05/2014 |
| <b>Date of translation</b> | 25/06/2014 |

This document summarises the data included in Test Report identified in the associated report no.

The results obtained in these tests only refer to the samples analysed at this Centre on the date shown and do not imply consistency in production quality.

In case of a lawsuit, the original Spanish associated report shall be taken as reference.