

Notice of Testing and Classification

COMPANY	JOSÉ LUIS MONTES SUÁREZ-BARANDILLAS TURIASSO
ADDRESS	Po. Ind. C/ Castilla y León 39 50500 TARAZONA (ZARAGOZA) SPAIN
ASSOCIATED REPORT No.	14_07323-4-a

TESTED SAMPLE

Railing base 40x40 adjustable «ref. 8008»

TEST REQUESTED

The testing requested regards **shear load**, carried out in accordance with internal procedures. Load is applied resulting in breakage of the part in order to verify the maximum allowable load.

RESULT

Test	Maximum load (N)*
Shear load	13785

*Equivalence 10 N = 1 kg

Date of test	09/10/2014
Date of issue	10/10/2014
Date of translation	10/10/2014

This document summarises the data included in Test Report identified in the associated report no. 14_07323-4

The results obtained in these tests only refer to the samples analysed at this Centre on the date shown and do not imply consistency in production quality.

In case of a lawsuit, the original Spanish associated report shall be taken as reference.